

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006629A-R2
DATE: 07/06/2006
CERTIFICATION PROGRAM: Structural
COMPANY: NanYa
CODE: 661-1
REVISION DATE: 03/10/2010

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Nan Ya Plastics USA 8989 North Loop East Houston, TX 77029</p>	<p>Series "Distinction Door" In-swing Fiberglass Clad Entry Door Configuration: OXXO Insulating Glass w/Laminate- Interior- 0.125" Annealed/0.090"PVB/0.125" Annealed/0.500" Air Space/Ext-0.125" Tempered Glass All Specimens: Frame: W-12'1" Panel: W-3'0" Opening: W-1'10" H-8'0" H-7'8" H-6'8"</p>

SPECIFICATION	PRODUCT RATING
<p>AAMA/NWDA 101/I.S.2-97 AAMA/WDMA 101/I.S.2/NAFS-02</p>	<p>HGD-R30 HGD-R30 3683 x 2438 (145" x 96")</p>

Product Tested By: Construction Consulting Laboratory, International
Report No: CCLI-06-046 (Structural)
Expiration Date: June 30, 2014

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122