


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009950B
DATE: 07/01/2009
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya
CODE: 661-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics USA 8989 North Loop East Houston, TX 77029	Series "Neuma Classic" In-Swing & Out-Swing Center Hinged Patio Door Configuration: O/X (1) Fixed Panel/ (1) Active Panel Glazing: IG-1/8" Tempered Glass Frame: W-1810mm(71.25") H-2096mm(82.5") DLO: W-635mm(25") H-1676mm(66") STP: Pos+75.0 psf Neg-75.0 psf

SPECIFICATION	PRODUCT RATING
ASTM E283-99/E330-02/E547-00	Out-Swing Design Pressure: +50/-50 psf In-Swing Design Pressure: +50/-50 psf

Product Tested By: Certified Testing Laboratories
Report No: CTLA-1973W/CTLA-1973W-1
Expiration Date: **June 30, 2013**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122