


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006486
DATE: 04/10/2006
CERTIFICATION PROGRAM: Structural
COMPANY: NanYa/Plastpro
CODE: P-409-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
NanYa Plastics Corporation U.S.A 8909 N. Loop E, Suite 800 Houston, TX 77029	Series "9'0" x 8'0" Fiberglass Outswing Glazed Double Door" Configuration: OXX Insulating Glass w/Laminate- Interior- 0.125" Annealed/0.090"PVB/0.125" Annealed/0.500" Air Space/Ext-0.125" Tempered Glass All Specimens: Frame:W-9'1" Panel:W-3'0" Opening:W-1'9" H-8'0" H-8'0" H-6'7"

SPECIFICATION	PRODUCT RATING
AAMA/NWDA 101/I.S.2-97 ASTM E330-02 AAMA 1302.5-76	HGD-LC50 Design Pressure: +50/-50 psf FER-Passed

Product Tested By: Certified Testing Laboratories
 Report No: CTLA-1420W-2(Structural/FER)
 Expiration Date: **February 28, 2010**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659